

Supplier	TOSHIBA CARRIER CORPORATION
----------	-----------------------------

Indoor unit	RAS-B16J2KVG-E
-------------	----------------

Outdoor unit	RAS-16J2AVG-E
--------------	---------------

Sound power level

indoor unit (cooling)	dB	58
-----------------------	----	----

outdoor unit (cooling)	dB	64
------------------------	----	----

indoor unit (heating)	dB	58
-----------------------	----	----

outdoor unit (heating)	dB	66
------------------------	----	----

Refrigerant

Type		R32
------	--	-----

Global Warming Potential	kgCO ₂ eq	675
--------------------------	----------------------	-----

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 1975. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 1975 times higher than 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

Cooling

Energy efficiency class		A++
-------------------------	--	-----

Design load (P _{designc})	kW	4.2
-------------------------------------	----	-----

Seasonal efficiency (SEER)		6.10
----------------------------	--	------

Seasonal electricity consumption (Q _{CE})	kWh/annum	241
---	-----------	-----

Heating

		Heating/Average	Heating/Warmer	Heating/Colder
Energy efficiency class		A+	A++	x
Design load (Pdesignh)	kW	3.6	1.9	x,x
Seasonal efficiency (SCOP)		4.00	4.90	x,xx
Seasonal electricity consumption (Q _{HE})	kWh/annum	1259	549	x
Back up heating capacity		kW	0.56	
Declared capacity for heating, at indoor temperature 20°C and outdoor temperature T_j.				
T _j = -7°C (Pdh)	kW	3.18	-	x,xx
T _j = 2°C (Pdh)	kW	1.94	1.94	x,xx
T _j = 7°C (Pdh)	kW	1.25	1.25	x,xx
T _j = 12°C (Pdh)	kW	1.03	1.03	x,xx
T _j =bivalent temperature (Pdh)	kW	3.18	1.94	x,xx
T _j =operation limit (Pdh)	kW	2.80	2.80	x,xx
T _j = -15°C (Pdh)	kW	-	-	x,xx